

VILLAGE OF LOMBARD
REQUEST FOR BOARD OF TRUSTEES ACTION
For Inclusion on Board Agenda
Bids and Proposals

TO : President and Village Board of Trustees
FROM : David A. Hulseberg, Village Manager
DATE : April 7, 2010 Agenda Date April 15, 2010
TITLE : Sewer Lateral Lining - Bid Waiver
SUBMITTED BY: Angela M. Podesta, Utilities Superintendent *AMP*

RESULTS:

Date Bids Were Published _____ Bidding Closed _____
Total Number of Bids Received _____
Total Number of Bidders Meeting Specifications _____
Bid Security Required _____ Yes _____ No
Performance Bond Required _____ Yes _____ No
Were Any Bids Withdrawn _____ Yes _____ No
Explanation:
Waiver of Bids Requested? _____ X Yes _____ No
If yes, explain:
Award Recommended to Lowest _____ Yes _____ No
Responsible Bidder?
If no, explain: Purchase from manufacturer's authorized distributor.

FISCAL IMPACT:

Engineer's estimate/budget estimate \$60,000.00
Amount of Award \$60,000.00

BACKGROUND/RECOMMENDATION:


Waive bids and award a contract to Performance Pipelining, Inc. for Sewer Lateral Lining Project in an amount not to exceed \$30,000.00 for Fiscal Year 2010 and \$30,000 for Fiscal Year 2011.

Has Recommended Bidder Worked for Village Previously X Yes _____ No
If yes, was quality of work acceptable X Yes _____ No
Was item bid in accordance with Public Act 85-1295? _____ Yes X No
Waiver of bids - Public Act 85-1295 does not apply X Yes

REVIEW (as needed):

Village Attorney XX _____ Date _____
Finance Director XX _____ Date _____
Village Manager XX _____ Date _____

NOTE: All materials must be submitted to and approved by the Village Manager's Office by 4:30 pm, Wednesday, prior to the Board Agenda distribution.



MEMORANDUM

To: David A. Hulseberg, Village Manager

From: Angela M. Podesta, Utilities Superintendent *AMP*

Through: Carl S. Goldsmith, Director of Public Works *CSG*

Date: April 6, 2010

Subject: Sewer Lateral Lining Contract

The Department of Public Works sent a Request for Proposal to Performance Pipelining, Inc. (PPI) of Ottawa, IL and Chicago Trenchless Rehabilitation (CTR) of Glenview, IL for lining sewer laterals from the sewer main to the clean out. This lining process essentially inserts a new pipe inside the existing pipe without excavation. Public Works conducted a pilot project in 2005 to evaluate the T-Liner process and found it to be acceptable. The T-Liner lines a portion of the sewer main at the connection and shoots a liner up the lateral to the clean out. The T-Liner is a patented process but CTR can also install a liner from main to clean out that includes covering the connection at the sewer main that Public Works considered acceptable.

Public Works has successfully used sewer lining for main line rehabilitation for many years. Public Works uses the sewer lateral lining process when a sewer lateral needs repair due to extensive root growth, cracks or other defects that can be remedied without replacing the pipe, thus reducing restoration costs and inconvenience to the residents. There are still instances when replacement is the only method that will fix the problem.

The prices submitted for the proposal are attached and based upon the projected work, staff recommends the contract be awarded to PPI. PPI has performed satisfactorily in the past. The Village has \$30,000 budgeted for Sewer Lateral Lining in the Water & Sewer Capital Reserve Fund for both Fiscal Years 2010 and 2011. The quantities in the proposal are estimates and work orders will be issued to identify the locations and quantities. Payment for work performed will be based upon measured quantities multiplied by the contract unit prices.

Please request the Board of Trustees waive bids and award a contract in an amount equal to the budgeted amount of \$30,000 for Fiscal Year 2010 and \$30,000 for Fiscal Year 2011 for sewer lateral lining to Performance Pipelining, Inc. of Ottawa, IL at their April 15, 2010 meeting.

FY 2010 Sewer Lateral Lining Project

April 5, 2010 4 p.m.

| <u>Item</u> | <u>Qty</u> | <u>Unit</u> | Chicago Trenchless Rehabilitation Glenview IL | | Performance Pipelining Inc Ottawa IL | |
|--|------------|-------------|--|--------------------|---|--------------------|
| | | | <u>Unit Price</u> | <u>Total Price</u> | <u>Unit Price</u> | <u>Total Price</u> |
| "T Style" Lining System (base price, up to and including 15 ft length, 8" main, 6" lateral) | 2 | EA | \$3,500 | \$7,000 | \$3,950 | \$7,900 |
| "T Style" Lining System (base price, up to and including 15 ft length, 10" main, 6" lateral) | 2 | EA | \$3,700 | \$7,400 | \$4,050 | \$8,100 |
| "T Style" Lining System (base price, up to and including 15 ft length, 12" main, 6" lateral) | 0 | EA | \$0 | \$0 | \$4,350 | \$0 |
| "T Style" Lining System (base price, up to and including 15 ft length, 15" main, 6" lateral) | 1 | EA | \$4,500 | \$4,500 | \$4,750 | \$4,750 |
| "T Style" Lining System (base price, up to and including 15 ft length, 21" main, 6" lateral) | 1 | EA | \$5,800 | \$5,800 | \$5,950 | \$5,950 |
| lateral) | 175 | FT | \$125 | \$21,875 | \$30 | \$5,250 |
| Mobilization | 2 | EA | \$1,500 | \$3,000 | \$300 | \$600 |

Total Proposal

\$49,575

\$32,550

Additional Items

| | | | | | | |
|---|---|----|-----|-----|-------|-----|
| By-Pass Pumping | 0 | HR | \$0 | \$0 | \$325 | \$0 |
| Alternate Access (Backyards, Easements) | 0 | EA | \$0 | \$0 | \$500 | \$0 |