

ORDINANCE NO. 6795

AN ORDINANCE AMENDING TITLE 15, CHAPTERS 150, SECTIONS 150.030 AND 150.105 OF THE VILLAGE CODE IN REGARD TO FIRE ALARM SYSTEM SUPERVISION

BE IT ORDAINED by the President and Board of Trustees of the Village of Lombard, DuPage County, Illinois, as follows:

SECTION 1: That Title 15, Chapter 150, Section 150.030 of the Lombard Village Code, which adopts by reference the International Building Code, 2009 Edition, and makes certain modifications thereto, is hereby amended by deleting Section 901.6.4 in its entirety.

SECTION 2: That Title 15, Chapter 150, Section 150.030 of the Lombard Village Code, which adopts by reference the International Building Code, 2009 Edition, and makes certain modifications thereto, is hereby amended so that Section 901.6 reads in its entirety as follows:

“Section 901.6 is changed to read as follows: Fire Protection System Supervision: All required fire protection systems shall be supervised by and terminate with the Village of Lombard Communications Center (DUCOMM), or such other central station monitoring service approved by the Fire Code Official.

Exceptions: Supervisory Service is not required for:

- (1) Single and multiple station smoke alarms required by 907.2.11 of the International Building Code, 2009 Edition.
- (2) Automatic sprinkler systems protecting one and two family dwellings.
- (3) Smoke detectors in GROUP I-3 occupancies.”

SECTION 3: That Title 15, Chapter 150, Section 150.105 of the Lombard Village Code, which adopts by reference the International Fire Code, 2009 Edition, and makes certain modifications thereto, is hereby amended so that Section 907.7.5 reads in its entirety as follows:

“Section 907.7.5 is changed to read as follows: Fire Protection System Supervision: All required fire protection systems shall be supervised by and

terminate with the Village of Lombard Communications Center (DUCOMM), or such other central station monitoring service approved by the Fire Code Official.

Exceptions: Supervisory Service is not required for:

- (1) Single and multiple station smoke alarms required by 907.2.11 of the International Building Code, 2009 Edition.
- (2) Automatic sprinkler systems protecting one and two family dwellings.
- (3) Smoke detectors in GROUP I-3 occupancies.”

SECTION 4: All ordinances and parts of ordinances in conflict with or inconsistent with the provisions of this Ordinance are hereby repealed to the extent of any such conflict or inconsistency.

SECTION 5: That if any part or portion of this Ordinance shall be declared invalid by court of competent jurisdiction, such invalidity shall not affect the remainder of this Ordinance.

SECTION 6: This Ordinance shall be in full force and effect from and after its passage, approval and publication in pamphlet form as provided by law.

Passed on first reading this _____ day of _____, 2013.

First reading waived by action of the Board of Trustees this 7th day of February, 2013.

Passed on second reading this 7th day of February, 2013.

Ayes: Trustees Gron, Giagnorio, Wilson, Breen, Fitzpatrick and Ware

Nayes: None


Absent: None

Approved this 7th day of February, 2013



William Ware, Acting Village President

ATTEST:



Brigitte O'Brien, Village Clerk

Published by me this 8th day of February, 2013



Brigitte O'Brien, Village Clerk