

VILLAGE OF LOMBARD
REQUEST FOR BOARD OF TRUSTEES ACTION
For Inclusion on Board Agenda
Bids and Proposals

TO: President and Village Board of Trustees

FROM: William T. Lichter, Village Manager

DATE: September 11, 2007 AGENDA DATE: September 20, 2007

TITLE: Bid Opening For: Madison & Ahrens San. MH Rem. & Repl.

SUBMITTED BY: David A. Dratmol, P.E., Village Engineer

RESULTS:

Date Bids Were Solicited 08/10/07 Bidding Closed 09/10/07
Total Number of Bids Received 2
Total Number of Bidders Meeting Specifications 2

Bid Security Required Yes No

Performance Bond Required Yes No

Were Any Bids Withdrawn Yes No

Explanation: Yes No

Waiver of Bids Requested? Yes No

If yes, explain: Due to emergency situation.

Award Recommended to Lowest Yes No

Responsible Bidder? Yes No

If no, explain:

FISCAL IMPACT:

Engineer's estimate/budget estimate \$ N/A / \$ N/A
Amount of Award \$48,000.00

BACKGROUND/RECOMMENDATION:


Has Recommended Bidder Worked for Village Previously Yes No
If yes, was quality of work acceptable Yes No
Was item bid in accordance with Public Act 85-1295? Yes No
Waiver of bids - Public Act 85-1295 does not apply Yes No

REVIEW (as needed):

Village Attorney XX _____ Date 9/18/07
Finance Director XX _____ Date 9/18/07
Village Manager XX _____ Date 9/12/07

NOTE: All materials must be submitted to and approved by the Village Manager's Office by 4:30 pm, Wednesday, prior to the Board Agenda distribution.

Interoffice Memorandum

To: William T. Lichter, Village Manager
 Through: Wes Anderson, Director of Public Works 
 From: David A. Dratnol, P.E., Village Engineer
 Date: September 11, 2007
 Subject: Sanitary manhole replacement at Madison St. & Ahrens Av.

Attached please find a contract pertaining to the removal and replacement of a 15 foot deep sanitary manhole. This work is for the permanent repair of the structure following the temporary repair for the failed structure and void under the pavement. With the depth of the structure and the major flows going through it, the project becomes quite challenging. The new structure will have a special concrete splash wall to dissipate the energy from the forcemain flow.

Kings Point General Cement Contractor of Bensenville, Illinois submitted the lowest proposal at \$48,000 which includes all restoration. Kings Point was the contractor for the Concrete Pavement Rehabilitation Project during this construction season. Their work has been satisfactory. A verbal quote was received from John Neri Construction in the amount of \$60,000.00. Due to the nature of the work, Staff is asking the Board to waive bids and award the contract to Kings Point.

Please present this proposal to the President and Board of Trustees for their review at their regular meeting of September 20, 2007. If approved, please have a signed copy returned to Engineering for further processing.

WBA/PK

U:/PAULK/Madison & Ahrens San MH BOT Memo.doc



**KINGS POINT
GENERAL CEMENT**

920 COUNTY LINE ROAD • BENSENVILLE, ILLINOIS 60106
TEL: 630-627-2178
630-766-3160
FAX: 630-627-2180

REVISED PROPOSAL

September 5, 2007

PROPOSAL SUBMITTED TO:
Village of Lombard
ATTN: Kent H.
255 East Wilson Ave.
Lombard, IL 60148

Project: Sanitary man hole remove and replace performed at
Aherns and Madison, Lombard, IL

ITEM:

1. Sanitary man hole removal and replacement: 6' x 14' 1 each
special with 44" x 41" x 34" high concrete splash: \$23,500.00
2. 10 L.F. 16" PVC: \$100 x 10 L.F.
3. 10 L.F. 8" PVC: \$60 x 10 L.F.
4. 10 L.F. 15" PVC: \$90 x 10 L.F.
5. 10 L.F. 21" PVC: \$120 x 10 L.F.
6. Traffic control: \$3,500
7. Trench backfill: L.S.
8. Street removal: 200 S.Y. x \$8.00
9. Street replacement 8" PCC: 200 S.Y. x \$40
10. 4 connections: L.S. \$ 5,200.00

TOTAL: \$48,000.00

**PLEASE NOTE: SAID PRICE IS GOOD FOR 30 DAYS FROM ABOVE DATE.
PLEASE SIGN AND MAIL BACK SAID PROPOSAL.**

Signature w/Deposit

[Handwritten Signature]
Authorized Signature
Val Rice, President

Date of Acceptance