

MEMORANDUM

TO: William T. Lichter, Village Manager

FROM: Nick Hatfield, PE, Development Engineer

DATE: January 4, 2008

SUBJECT: ACCEPTANCE OF PUBLIC WATER MAIN AND FIRE HYDRANTS LOCATED AT 845-855 EAST 22ND STREET (RESIDENCES OF FOUNTAIN SQUARE), IN LOMBARD, ILLINOIS

The Private Engineering Services Division of the Community Development Department recommends that the Board of Trustees accept the public water main, valves and fire hydrants constructed for the Residences of Fountain Square Development at 845-855 E. 22nd Street have been constructed substantially per plan and have passed all required tests. Attached is the updated utility map. Please present the attached resolution to the Board of Trustees at their January 17, 2008 meeting.

The stated improvements are acceptable since they were installed substantially to plan and have passed all required tests. The Private Engineering Services Division has approved the project record drawings. Please note that the public water main does not include the service lines after the valve vaults and all storm sewer, sanitary sewer and eight-inch, six-inch and four-inch watermain on private property are the responsibility of the owner.

The Department has obtained a two-year bond guaranteeing the improvements.

NH:nh

H:\CD\WORDUSER\PES\Nick\Memos\Public Improvement Acceptance\Residences of Fountain Square\Memo - PES to VM.doc

cc: David A. Hulseberg, AICP, Asst. Village Mgr. and Director of Community Development
David P. Gorman, PE, Acting Director of Public Works
Angela Podesta, Utilities Superintendent