

VILLAGE OF LOMBARD
REQUEST FOR BOARD OF TRUSTEES ACTION
For Inclusion on Board Agenda
Bids and Proposals

TO : President and Village Board of Trustees
FROM : David A. Hulseberg, Village Manager
DATE : December 18, 2009 Agenda Date January 7, 2010
TITLE : Olde Towne Lift Station Pumps - Bid Waiver
SUBMITTED BY: Angela M. Podesta, Utilities Superintendent *AMP*

RESULTS:

Date Bids Were Published _____ Bidding Closed _____
Total Number of Bids Received _____
Total Number of Bidders Meeting Specifications _____
Bid Security Required _____ Yes _____ No
Performance Bond Required _____ Yes _____ No
Were Any Bids Withdrawn _____ Yes _____ No
Explanation:
Waiver of Bids Requested? _____ X Yes _____ No
If yes, explain:
Award Recommended to Lowest _____ Yes _____ No
Responsible Bidder?
If no, explain: Purchase from manufacturer's authorized distributor.

FISCAL IMPACT:

Engineer's estimate/budget estimate \$34,786.94
Amount of Award \$34,786.94

BACKGROUND/RECOMMENDATION:


Waive bids and award a contract to ITT Flygt for the purchase of three (3) pumps for the Olde Towne Lift Station in an amount not to exceed \$34,786.94.

Has Recommended Bidder Worked for Village Previously X Yes ___ No
If yes, was quality of work acceptable X Yes ___ No
Was item bid in accordance with Public Act 85-1295? ___ Yes X No
Waiver of bids - Public Act 85-1295 does not apply X Yes

REVIEW (as needed):

Village Attorney XX _____ Date _____
Finance Director XX _____ Date _____
Village Manager XX _____ Date _____

NOTE: All materials must be submitted to and approved by the Village Manager's Office by 4:30 pm, Wednesday, prior to the Board Agenda distribution.



MEMORANDUM

To: David A. Hulseberg, Village Manager
From: Angela M. Podesta, Utilities Superintendent *AMP*
Through: Carl S. Goldsmith, Director of Public Works *g*
Date: December 17, 2009
Subject: Olde Towne Lift Station Pump Replacement

Background

The Olde Towne Lift Station was built in 1997 as part of the Olde Towne Project to facilitate the separation of combined sewers. Initially the lift station was sized to serve the area west of Main Street, knowing that when the Olde Towne East Project east of Main Street was completed, the lift station would have to be retrofitted with larger pumps. The IEPA permit for the lift station was issued for the higher capacity pumps.

There are several components to this lift station upgrade and they are being installed independently of each other to keep the lift station operational at all times.

- A 20" valve was installed on the inlet pipe to enable the wet well to be isolated so crews can work in the wet well.
- The control panel needs to be upgraded to accommodate the larger pumps.
- New conduit needs to be installed from the wet well to the new control panel.
- New pumps will be installed.

In 2000, the Village developed a standard for lift station construction. The Village's standard pump is manufactured by ITT Flygt Pumps. Flygt has submitted a quote for three (3) new pumps in an amount not to exceed \$34,786.94. This project is being funded by the Water & Sewer Capital Reserve Fund.

Recommendation

Please request the Board of Trustees to waive bids and award a contract in an amount not to exceed \$34,786.94 for three (3) submersible pumps for the Olde Towne Lift Station to ITT Flygt of Tinley Park, IL at their January 7, 2010 meeting.



ITT

December 4, 2009

VILLAGE OF LOMBARD
255 EAST WILSON
LOMBARD IL 60148

*ITT Water & Wastewater U.S.A.
Flygt Products*

8402 183rd Street Suite A
Tinley Park, IL 60487
Tel (708) 342-0484
Fax (708) 342-0491

Quote # 2009-CHI-1735

Re: Yeomans Retrofit - Old Town LS

Dear Mr. Ryan:

Flygt Corporation is pleased to provide a quote for three NP3171 pumps rated for 993gpm at 65.3' TDH and shall operate on 460 volt 3 phase power. The pumps are 30 HP and equipped with 75' of sub cab and an FLS moisture/thermal sensor that works in conjunction with the MINI CAS unit. The pumps are drilled for installation of a mixed flush valve and the volute face is drilled to bolt to a Yeomans flange .

Pumps

Qty	Description
3	Flygt Model NP-3171.091 6" volute Submersible pump equipped with a 460 Volt / 3 phase / 60 Hz 30 HP 1750 RPM motor, 435 impeller, 1 x 50 Ft. length of SUBCAB 4AWG/3-2-1-GC submersible cable, FLS leakage detector, volute is prepared for Flush Valve, Explosion proof
75	CABLE,SUBCAB AWG 4/3-2-1-GC+ 33.8MM

Pumps Price USD \$ 33,962.94

Start Up

Qty	Description
1	START UP CHARGE - NO TAX

Start Up Price USD \$ 824.00

Total Project Price \$ 34,786.94

This Quote is valid for sixty (60) days.


Terms of payment: Net 60 Standard


Warranty: Standard warranty terms apply to the items in this quotation.

Time of delivery: Approx. 10 working weeks after receipt of a purchase order.

Thank you for the opportunity to provide this quotation. Please contact me if you have any questions.

Sincerely,





Shannon McMahon

Municipal Sales

Phone: 708/781-0177

Cell: 708/990-4919

shannon.mcmahon@itt.com



VILLAGE OF LOMBARD

CONTRACT

This agreement is made this 7th day of January, 2010, by and between, and shall be binding upon, the Village of Lombard, an Illinois municipal Corporation hereinafter referred to as (the "Village") and (_____) referred to as (the "Contractor").

Witnesseth That in consideration of the mutual promises of the parties delineated in the Contract Documents, the Contractor agrees to sell and the Village agrees to pay for the following described items as set forth in the Contract Documents:

Three (3) Flygt Model NP-3171.091 6" Submersible pumps and cable
in an amount not to exceed \$34,786.94

1. This Contract shall embrace and include all of the applicable Contract Documents listed below as if attached hereto or repeated herein:
 - a. The Contractor's Quotation #2009-CHI-1735 Dated December 4, 2009
 - b. Required Certificate of Insurance
2. The Village agrees to pay, and the Contractor agrees to accept as full payment for the items which are the subject matter of this Contract the total sum of \$34,786.94 paid in accordance with the provisions of the Local Government Prompt Payment Act and the provisions of the Contract Documents.
3. Risk of loss, destruction or damage of or to goods under this Contract shall be on contractor until delivery of the goods to the Village and acceptance of the goods by the Village.
4. Contractor agrees to perform the terms of this Contract by May 15, 2010. Time is of the essence of this Contract.
5. Where the terms of this Contract conflict with the provisions of the Contract Documents, the Contract Documents shall be binding.

IN WITNESS WHEREOF, the Village of Lombard, Illinois by William J. Mueller, Village President, and the Contractor have hereunto set their hands this 7th day of January, 2010.

If an individual or partnership, all individual names of each partner shall be signed or if a corporation, an officer duly authorized shall sign here:

Accepted this ___ day of _____, 20__.

Individual or Partnership _____ Corporation _____

By Position/Title

By Position/Title

Print Company Name

THE VILLAGE OF LOMBARD, ILLINOIS

Accepted this 7th day of January, 2010.

William J. Mueller
Village President

Attest:

Brigitte O'Brien
Village Clerk